

127567

Receipt No.

Livingston County Health Department

Environmental Health Division

2300 E Grand River, Howell, Michigan 48843-7579

Fax (517) 546-9853 • Phone (517) 546-9858

S. 29,690

ID No

Prop Description No

SOILS EVALUATION FOR SUB-SURFACE SEWAGE DISPOSAL SYSTEMS

Location and Directions

1 mile South of Mason off Kern Rd.

Brenda Whalen

Requestor

Robin Dymond

Owner

SOIL DESCRIPTION			SKETCH	
Ft.	(1)	(2)	Ft.	
1	Topsoil	Topsoil	1	
2	Sandy	Loamy	2	
3	Loam	Sand	3	
4	Coarse		4	
5			5	
6			6	
7			7	
8			8	
9			9	
10			10	
11			11	
12			12	

- Suitable
- Unsuitable
- Suitable with Special Restrictions
- Further Info. Needed (Refer to Comments)

Comments Locate system in area of soil borings. 100% cutdown to sand at 2 to 3 ft. Lay system. Max. cover 2 ft. Min. cover 1 ft. Install tank filter.

Harry Good

Environmental Health Representative

6-30-98

Date

Soils evaluation based on criteria stated in Livingston County Sanitary Code, effective January 4, 1993

This is **NOT** a permit. A suitable soils rating is **NOT** a guarantee that a permit to construct an on-site subsurface sewage disposal system will be granted. Changing conditions that might result in permit denial are explained in more detail on the reverse side.

Location Talonna Trail
 Township Tosco
 Section No 2
 Subdivision/Acreage 4.9
 Lot, Parcel AY